


Cooling Tower Drift Loss (Standard Data)

SPX

Cooling Technologies

Balcke | Hammen Dry Cooling | Marley

Drift Loss as a Function of the Droplet Size
(Total Drift Loss = 0.0005% of water flow rate)



Droplet Drift Rate for CTS Cooling Towers


Methodology for calculating salt particle size from drift droplets taken from "Calculating Realistic PM10 Emissions from Cooling Towers", Reisman and Frisbie, *Environmental Progress*, July 2002. Drift droplet sizes estimated from SPX Drift Loss Curve for 0.0005% assumed to be representative of 0.0004% drift efficiency tower.

Salt Content	1.75	wt. %	MACTEC estimate for annual average worst-case									
Cycles of Concentration	2		From CCNPP Unit 3 ER, Table 3.4-2					From Reisman and Frisbie				
Salt Density	2.20	gm/cc	Droplet Volume (cu. um)	Droplet Mass (ug)	Droplet Salt mass (ug)	Droplet Salt Volume (cu. um)	Salt Droplet Diameter (um)	Droplet Fraction (Estimated from SPX Figure)	Droplet Fraction Contributing to Particles Below 10 um	Droplet Fraction Contributing to Particles Below 2.5 um	Calculated Droplet Size Distribution* (Percent)	
10	524	5.2E-04	1.8E-05	8.3E+00	2.5	0.00007	0.00007	0.00007	0.13	Total	13.0	
20	4,189	4.2E-03	1.5E-04	6.7E+01	5.0	0.00010	0.00010	0.00010		Fraction 2.5 um & below	18.5	
30	14,137	1.4E-02	4.9E-04	2.2E+02	7.5	0.00013	0.00013	0.00013			24.1	
40	33,510	3.4E-02	1.2E-03	5.3E+02	10.1	0.00012	0.00012	0.00012			22.2	
50	65,450	6.5E-02	2.3E-03	1.0E+03	12.6	0.00009	0.8	0.8			16.7	
60	113,097	1.1E-01	4.0E-03	1.8E+03	15.1	0.00003					5.6	
70	179,594	1.8E-01	6.3E-03	2.9E+03	17.6	0					0	
80	268,083	2.7E-01	9.4E-03	4.3E+03	20.1	0					0	
90	381,704	3.8E-01	1.3E-02	6.1E+03	22.6	0					0	
100	523,599	5.2E-01	1.8E-02	8.3E+03	25.2	0					0	
110	696,910	7.0E-01	2.4E-02	1.1E+04	27.7	0					0	
120	904,779	9.0E-01	3.2E-02	1.4E+04	30.2	0					0	
						0.00055	Total		Total Fraction 10 um & below		100.0	

* e.g., 0.00007 / 0.00055 x 100 = 13%

Cooling Tower Drift Loss (Standard Data)

Drift Loss as a Function of the Droplet Size
(Total Drift Loss = 0.005% of water flow rate)



Droplet Drift Rate for ESWS Cooling Towers

Methodology for calculating salt particle size from drift droplets taken from "Calculating Realistic PM10 Emissions from Cooling Towers", Reisman and Frisbie, *Environmental Progress*, July 2002. Drift droplet sizes estimated from SPX Drift Loss Curve for 0.005.

Influent Salt Content for ESWS Towers	0.37	wt. %											Calculated Droplet Size Distribution* (Percent)
Cycles of Concentration	2												
Salt Density	2.20	gm/cc <th colspan="10"></th> <td></td>											
Droplet Diameter (um)	Droplet Volume (cu. um)	Droplet Mass (ug)	Droplet Salt mass (ug)	Droplet Salt Volume (cu. um)	Salt Droplet Diameter (um)	Droplet Fraction (Estimated from SPX Figure)	Droplet Fraction Contributing to Particles Below 10 um	Droplet Fraction Contributing to Particles Below 2.5 um					
10	524	5.2E-04	3.9E-06	1.8E+00	1.5	0.00033	0.00033	0.0003				6.4	
20	4,189	4.2E-03	3.1E-05	1.4E+01	3.0	0.00050	0.00050	0.0005				9.7	
30	14,137	1.4E-02	1.1E-04	4.8E+01	4.5	0.00083	0.00083	0.16	Total Fraction 2.5 um & below			16.1	
40	33,510	3.4E-02	2.5E-04	1.1E+02	6.0	0.00104	0.00104					20.1	
50	65,450	6.5E-02	4.9E-04	2.2E+02	7.5	0.00108	0.0011					20.9	
60	113,097	1.1E-01	8.4E-04	3.8E+02	9.0	0.00071	0.0007					13.7	
70	179,594	1.8E-01	1.3E-03	6.1E+02	10.5	0.00033	0.0003					6.4	
80	268,083	2.7E-01	2.0E-03	9.1E+02	12.0	0.00017	0.93	Total Fraction 10 um & below			3.2		
90	381,704	3.8E-01	2.8E-03	1.3E+03	13.5	0.00008					1.6		
100	523,599	5.2E-01	3.9E-03	1.8E+03	15.0	0.00004					0.8		
110	696,910	7.0E-01	5.2E-03	2.4E+03	16.5	0.00002					0.4		
120	904,779	9.0E-01	6.7E-03	3.1E+03	18.0	0.00003					0.6		
TOTAL						0.000518						100.0	

* e.g., 0.00033 / 0.00518 x 100 = 6.4%